



Confined Space/ Register

Definition

A 'confined space' means an enclosed or partially enclosed space that:

- is not designed or intended to be occupied by a person
- is, or is designed or intended to be, at normal atmospheric pressure while any person is in the space; and
- is or is likely to be a risk to health and safety from:
 - an atmosphere that does not have a safe oxygen level, or
 - contaminants, including airborne gases, vapours and dusts, that may cause injury from fire or explosion, or
 - harmful concentrations of any airborne contaminants, or engulfment

This Confined Space register provides information on:

- Location of confined space
- Photo identification

Note: This is not a risk assessment. Persons accessing the Confined Space must conduct a risk assessment and SWMS/JSA relevant to the task they are undertaking prior to entering the confined space.

Work permit with SWMS required for entry into confined space

Where pits need to be emptied University of Adelaide strongly recommends the use of the vacuum system.

This Register excludes 3rd party asset owners pits e.g. SA Water, SAPN and Telstra

Campus:

Waite

At time of distribution the University of Adelaide has identified all known Confined Spaces. If you are aware or become aware of any confined spaces not identified in this document, can you please email the details to facilitiesupport@adelaide.edu.au

Confined Spaces Register - Waite

Name of Building/Area	Building Number/ Map reference	Location Description	Nature of the space	Photo	Signed	Permission to Work	Key required from Security
Claremont House	14/G8	East of House	Storage Tank/Vat		No	Yes	No
Plant Accelerator Building	40/G6	North West End Building	Storage Tank/Vat		No	Yes	No
Plant Accelerator Building	40/G6	South East of Building	Pit x2		No	Yes	No
Plant Accelerator Building	40/G6	East and North Valve Pits	Pit x2		No	Yes	No
Plant Accelerator Building	40/G6	West of Building	Trade Waste Pit x2		No	Yes	No
Plant Accelerator Building	40/G6	Northwest building	Tanks		No	Yes	No

Plant Accelerator Building	40/G6	West of Building	Pump Pit		No	Yes	No
Plant Accelerator Building	40/G6	East/South Plant Room	Trade Waste Pit x2		No	Yes	No
Plant Accelerator Building	40/G6	West side	Tanks		No	Yes	No
Plant Accelerator Building	40/G6	West side	Rainwater Tanks		No	Yes	No
Plant Accelerator Building	40/G6	South Side	Rainwater Tanks		No	Yes	No
Wine Innovation East	78/G6	North East of Building	Trade Waste Pit		No	Yes	No
Wine Innovation East	78/G6	South East of Building	Glycol tanks		Yes	Yes	No



Wine Innovation East	78/G6	West of Building	Trade Waste Pit		No	Yes	No
Wine Innovation Central	76/G6	North	Gatic Pit x3		No	Yes	No
Wine Innovation Central	76/F5	North West	Trade Waste Pit x3	Unable to locate			
Wine Innovation Central	76/F5	North West corner	Stormwater Pit	Not a confined space			
Wine Innovation Central	76/F5	Plant room 1.46	Storage Tank x2		No	Yes	No
Breeding Field Operations	35/G5	South West corner	Sewer Pit		No	Yes	No
Mudungerie Car Park	H4	South west corner	Stormwater Pit x5		No	Yes	No
Davies Building	34/G4	South of Building	Pit		No	Yes	No

Davies Building	34/G4	West	Sewer x3		No	Yes	No
Roadway – Next to childcare centre	G3	Paratoo Road	Sewer		No	Yes	No
Childrens Centre	11/G3	South West corner	Pit		No	Yes	No
McLeod House	37/E2	South of Building	Pit		No	Yes	No
Southern Barns - Soils Lab	63/F2	North of Building	Pit		No	Yes	No
Southern Barns – General Teaching Lab	61/F2	North of building - in garden	Pit		No	Yes	No
Southern Barns - Wine Sensory Lab	62/F2	Southern Barns, Room 92	Under Floor Cavity	Unable to find			

Urrbrae House	73/E1	Ground	Pump Pit		No	Yes	No
Charles Hawker Building	13/D2	West of Building	Sewer/Neutralising Pits		No	Yes	No
Charles Hawker Building	13/D2	Room B01 - Western Basement - Corridor	Under Floor Cavity		Yes	Yes	Yes
Waite Building	74/D2	Room LG09 – Male toilet	Under Floor Cavity		No	Yes	No
Waite Building	74/D2	Room GS02 -sub floor LG13	Under Floor Cavity		Yes	Yes	Yes
Waite Building	74/D2	Room LG01C	Under Floor Cavity	Unable to find			
Waite Building	74/D2	Northern Court yard	Sewer Pit		No	Yes	No

Waite Building	74/D2	Front lawn	Well		No	Yes	Yes
Containment Glasshouse	12/D3	South West corner	Trade Waste Pit		No	Yes	No
Soil & Water Field Laboratory	70/D3	Outside Building & Room 98	Pit		No	Yes	No
Agriculture, Food & Wine Office	80/E3	G13	Under Floor Cavity		No	Yes	Yes
Agriculture, Food & Wine Office	80/E3	North Side of Building	Sewer Pit		No	Yes	No
Agriculture, Food & Wine Office	80/E3	Western Basement	Pit	Not a Confined Space			
Conservation reserve		Refer Campus Services for directions	Concrete Tanks x3		No	Yes	No

Alverstoke Orchard	85/C4		Plastic Tank		Yes	Yes	No
Plant Genomics Centre	44/E4	Near carpark roadway	Bio Security Waste x2		Yes	Yes	No
Plant Genomics Centre	44/E4	West side of entry - Car park	Storm Water Pit		Yes	No	No
Waite Building	74/D2	Between 10E & 10D	Concrete Tanks x3	Unable to Find			
Waite Building	74/D2	Between 10E & 10D	Trade Waste Pit	Unable to find			

